



Item	Description	BRC code
BD1	blow down 80 lt	27BMIF273080D
BV0	inlet hand ball valve DN32,PN350	CD480106
CW1	W compressor	PR480110
CV1	check valve 3/4"	CD480102V
F1	Gas filter , PS= 100 bar , 25 micron	CD480017
SV0	safety valve calibrated 49 bar, inlet DN 20, discharge DN25	CD480194A
PG1	1/4" pressure gauge 60 bar	CD480156
PG2	1/4" pressure gauge 250 bar	CD480160-1
BV1	hand ball valve G1/4	CD480105
BV2 BV3 BV4	hand ball valve G3/8	CD480125
BV5	hand ball valve G1/2	CD480109
BV6 BV7 BV8 BV9	hand ball valve G3/4	CD480058
PV1	carbon steel ball valve with spring return pneumatic actuator, normally closed, 2 ways, DN32 PN350 bar	CD480093
PV2	carbon steel ball valve with spring return pneumatic actuator, normally closed, 2 ways, DN20 PN315 bar	CD480048
ST1	storage tanks (200 bar) PS=275 bar	PR480102
SV1	safety valve calibrated 242 bar, inlet DN20, discharge DN 25	CD480046A
△	connection to VENT	PR480074

E' vietato consegnare a terzi o riprodurre questo documento.
 Utilizzarne il contenuto o renderlo comunque noto a terzi
 senza autorizzazione. Ogni infrazione comporta il risarcimento
 dei danni subiti. Sono riservati tutti i diritti derivanti dalla
 concessione di brevetti per invenzioni, di modelli industriali di
 utilità e di disegni o modelli. (UNI ISO 16016)

M.T.M. s.r.l.
 SOCIETA' UNIPERSONALE
 Via La Morra 1 - 12062 -
 Cherasco (Cn), Italy
 Tel. +39 0172 48681
 Fax +39 0172 593113
 http://www.brc.it
 e-mail:r&s@brc.it



Disegno n°:	0350801		REV.	DATA	MODIFICHE		FIRMA
Item n°:	Commissa/Job :		Titolo/Title :		P&I compression station		
Scala/ scale:	Disegnatore :		Data :	Firma :	Sostituisce il/ Replaces:		
	M.Sartirano		23/11/07				
	Verificatore :		Data :	Firma :	Sostituito da/ Replaced by:		
	M.Galletta		23/11/07				
Formato :	Approvatore :		Data :	Firma :	Tavola/Sheet:		
A3	P.Abellonio		23/11/07		1/1		