



| symbol | description | quantity |
|----------------|--|------------|
| BV23 BV22 | hand ball valve G1/4 | CD480105 |
| BV26 BV25 BV24 | hand ball valve G3/8 | CD480125 |
| F4 | Gas filter , PS= 50 bar , 25 micron | CD480017 |
| F5 | Gas filter , PS= 100 bar , 25 micron | CD480018 |
| HE2 | CNG/H2O heat exchanger , PS=40 bar | CD480013 |
| HE3 | CNG/H2O heat exchanger, PS=100 bar | CD480012 |
| HE4 HE5 | coaxial pipes heat exchanger diam 35mm (PN160) for H2O and 20mm (PN320) for CH4 | FE488834 |
| PG7 PG14 | pressure gauge: 250 bar | CD480057-1 |
| PG8 | pressure gauge: 40 bar | CD4800157 |
| PG9 | pressure gauge: 100 bar | CD480133 |
| PS3 | pressure switch 230 calibrated | CD480098 |
| PT1 PT2 PT3 | pressure transducer: 0 - 250 bar | CD480043 |
| PT0 | pressure transducer: 0- 25 bar | CD480040 |
| PV1 | carbon steel ball valve with double acting pneumatic actuator, 2 ways, DN50 PN 16, Split Wafer | CD480035 |
| PV4 | carbon steel ball valve with double acting pneumatic actuator, 2 ways, DN20, PN315 | CD480045 |
| PV2 | carbon steel ball valve with double acting pneumatic actuator, 2 ways, DN32, PN 64 | CD480037 |
| PV3 | carbon steel ball valve with double acting pneumatic actuator, 2 ways, DN25, PN 315 | CD480041 |
| SV1 | calibrated safety valve 35 bar, inlet DN20, discharge DN 25 | CD480066A |
| SV2 | calibrated safety valve 90 bar, inlet DN20, discharge DN 25 | CD480067A |
| SV8 | calibrated safety valve 242 bar, inlet DN20, discharge DN 25 | CD480046A |
| TC1 TC2 TC3 | collar thermocouple | CD480039 |
| △ | connection to vent | PR480074 |

E' vietato consegnare a terzi o riprodurre questo documento.
 Utilizzarne il contenuto o renderlo comunque noto a terzi
 senza autorizzazione. Ogni infrazione comporta il risarcimento
 dei danni subiti. Sono riservati tutti i diritti derivanti dalla
 concessione di brevetti per invenzioni, di modelli industriali di
 utilità e di disegni o modelli. (UNI ISO 16016)

M.T.M. s.r.l.
 SOCIETA' UNIPERSONALE
 Via La Morra 1 - 12062 -
 Cherasco (Cn), Italy
 Tel. +39 0172 48681
 Fax +39 0172 593113
 http://www.brc.it
 e-mail:r@s@brc.it



| | | | | | |
|---------------|-------------|--|---|----------|-----------------------------------|
| Disegno n°: | 0360802 | | 1 | 07/10/07 | Spostato pressostato e sensore MP |
| Item n°: | | | REV. | DATA | MODIFICHE |
| Scala/ scale: | | | FIRMA | | |
| Formato: | A3 | | Titolo/Title: P&I compressor | | |
| Disegnatore: | M.Sartirano | | Commissa/Job: W160-036 EKO TRANS LTD | | |
| Verificatore: | M.Galletta | | Data: | 20/11/07 | Firma: |
| Approvatore: | P.Abellonio | | Data: | 20/11/07 | Firma: |
| | | | | | Sostituisce il/ Replaces: |
| | | | | | Sostituito da/ Replaced by: |
| | | | | | Tavola/Sheet: 1/1 |